

Addison Athletic Club Existing HVAC Equipment

Equipment	Age	Expected Life
Chiller	20 years	20-23 years
Cooling Tower	20 years	30-34 years
Boiler #1	30 years	25-30 years
Package Unit #1	15 years	13-15 years
Package Unit #2	15 years	13-15 years
Package Unit #3	15 years	13-15 years
Package Unit #4	15 years	13-15 years
Package Unit #5	15 years	13-15 years
Air Handling Unit #1	30 years	15-20 years
Air Handling Unit #2	30 years	15-20 years
Air Handling Unit #3	30 years	15-20 years
Air Handling Unit #4	12 years	15-20 years
Air Handling Unit #5	30 years	15-20 years
Air Handling Unit #6	30 years	15-20 years
Air Handling Unit #7	30 years	15-20 years
Air Handling Unit #8	15 years	15-20 years
Air Handling Unit #9	15 years	15-20 years
Air Handling Unit #10	30 years	15-20 years
Pump #8	30 years	15-20 years
Pump #9	30 years	15-20 years
Pump #10	30 years	15-20 years